

### CERTIFICATE OF ANALYSIS

**Customer :** Paul Sakson Environmental  
154 PO Box  
Leonardo, NJ 07737

**Project ID :** Holy Cross Preschool, 40 Mercer Ave, North Plainfield NJ  
**PAS Project ID :** P25-03350

**Matrix :** Drinking Water  
**Report Date :** 5/12/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03350-01	Pre-K Owls Faucet	Copper	87.4	ug/L	1	50.0	22.6	1300 *	SM 3111 B	4/18/25 08:30	5/5/25 15:20
P25-03350-01	Pre-K Owls Faucet	Lead	15.9	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 08:30	4/29/25 20:06
P25-03350-02	Boys Right Sink	Copper	87.4	ug/L	1	50.0	22.6	1300 *	SM 3111 B	4/18/25 08:35	5/5/25 15:24
P25-03350-02	Boys Right Sink	Lead	7.00	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 08:35	4/29/25 20:11
P25-03350-03	Girls Left Sink	Copper	63.1	ug/L	1	50.0	22.6	1300 *	SM 3111 B	4/18/25 08:37	5/5/25 15:25
P25-03350-03	Girls Left Sink	Lead	1.86 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 08:37	4/29/25 20:15

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol



Kelly Hogan - Quality Assurance Officer

